









LEYENDA ILUMINACIÓN Planta Segunda						
	Luminaria OPPLÉ Panel 595 UGR 19 30 W o similar.	(142 UD)				
	Luminaria OPPLÉ Panel 595 UGR 22 34 W o similar.	(30 UD)				
	Luminaria OPPLÉ MW R200 15W o similar.	(18 UD)				
		Luminaria OPPLÉ E COMAX R200 24W o similar.	(7 UD)		Eq. regulación Occuswitch Dali BMS LRM 2090 BMS de Philips o similar.	(13 UD)
		Luminaria OPPLÉ E COMAX R150 12W o similar.	(8 UD)		Eq. detección movimiento LRM 1000/LRM1010 Philips o similar.	(14UD)
		Luminaria OPPLÉ E ESTANCA ECOMAX 43W o similar.	(2 UD)			

**ACV** Estudio de Arquitectura  
Castro Vázquez

**PROYECTO BÁSICO Y DE EJECUCIÓN  
REHABILITACIÓN INTEGRAL DEL IES MURALLA DE LUGO**

TÍTULO: ILUMINACIÓN. PLANTA SEGUNDA

PAQUETE: INSTALACIONES

ARQUITECTO: José Manuel Castro Vázquez [Doctor]

Escala: 1/125	Revisión: *	Plano: I-02
EXPEDIENTE: ED51.18 MSRP	FECHA: Febrero 2019	
SITUACION: Rúa Angelo Colocci, s/n, 27003 Lugo	PROMOTOR: Consellería de Educación, Universidade e Formación Profesional, XUNTA DE GALICIA	